Electrical Safety Compliance Checklist



Here's a Checklist you can have workers fill out before performing work on energized electrical equipment to ensure that all required safety measures are in place. You may need to adapt this Checklist in accordance with the specific hazards, work conditions and safety measures at your own workplace.

GENERAL

Item	Yes	No	Comments
All employees who work on, near or with facility wiring or electrical conductors are			
trained as either qualified or unqualified workers			
Unqualified persons are trained in and familiar with any electrically related safety			
practices not covered by this standard but necessary for their safety			
Qualified persons are trained in and familiar with:			
Skills and techniques for distinguishing exposed live parts from other parts of			
electric equipment			
Voltage determination			
Clearance distances that must be maintained			
Training has been specific to the hazards to which the employee may or will be			
exposed			
SAFE WORK PRACTICES			
Work practices used to prevent electric shock and other injuries address de-			
energized parts which may be energized			
Work practices used to prevent electric shock and other injuries address de-			
energized parts which may be energized			
Procedure provided for work on or near exposed de-energized parts includes:			
Written procedures specific to the equipment or worksite			
De-energizing equipment			
Application of locks and tags			
All employees near enough to be exposed to a hazard have been trained, and are aware			
of the practices that must be followed to protect them from the hazard			

Item	Yes	No	Comments
Only qualified employees work on energized parts			
Only qualified employees work on energized parts			
Unqualified persons working near overhead lines are aware that they may not come approach, or use conductive objects closer than 10 feet for lines up to 50 kV, or 10 feet plus 4 inches for every 10 kV over 50 kV required			
Qualified persons have a working knowledge of allowable approach distances			